

DECLARATION OF COMPLIANCE

For the use of Penny & Giles SRS and SLS products in hazardous atmospheres

In compliance with the requirements of the ATEX Directive 2014/34/EU and ATEX Directive 1999/92/EC, Penny & Giles SRS and SLS series products have been assessed against the relevant parts of the following standards:

1. The Penny & Giles SRS and SLS series products are potentiometers and as such are classed as 'simple apparatus' according to the definition in paragraph 3.5.5 of BS EN 60079-14:2014.
2. 'Simple apparatus' is not certified, but may be used as part of an intrinsically safe circuit providing it is used with a suitable interface of associated apparatus (e.g. a safety barrier).
3. The SRS and SLS products also comply with the more onerous requirements for 'simple apparatus' defined in paragraph 5.7(a) of BS EN60079-11:2012. This definition requires consideration of further aspects, as discussed below:
 - 1) The products do not achieve safety by the inclusion of current and/or voltage limiting devices.
 - 2) The products do not contain any means of increasing the available voltage or current.
 - 3) Penny & Giles have carried out tests to ensure that the insulation between any of the externally available connections of the SRS and SLS products, and any externally accessible metal component of the body of the product will withstand 500Vrms or 707Vdc without breakdown.
 - 4) The SRS and SLS products have external accessible plastic components. When these products are used in hazardous areas, precautions must be applied to ensure that they are not rubbed, placed in the path of a fast moving dust flow or subjected to any other conditions that may lead to the build up of a static charge.

The external metal cases of the SRS and SLS products are made from an aluminium alloy with a content by mass of no more than 7.5% in total of magnesium, titanium and zirconium. Care should be taken to ensure that the case will not be subjected to impact, friction or any other condition which could lead to the production of sparks (see, for example, the requirements stated in BS EN60079-26:2015). The same precautions apply to the aluminium laminate labels used on both the SRS and SLS products.

- 5) Provided power dissipation in the SRS and SLS products is limited to no more than 1W, then the products will satisfy the T4 temperature classification of Group II apparatus at an ambient temperature 80°C. Penny & Giles can assist where use outside of these limitations is required.
- 6) Where SRS or SLS products are to be located where Category 1G and M1 equipment is normally required, it is the responsibility of the system design authority to ensure that the apparatus shall also comply with the additional requirements of BS EN60079-0:2012 or BS EN50303:2000 as applicable. Penny & Giles will assist with the provision of further information should this be required.

Where 'simple apparatus' forms part of an apparatus containing other electric circuits, then the combination of apparatus shall be considered as a whole. 'Simple apparatus' is required to be clearly identified when it is installed and it is the responsibility of the system design authority to obtain, where necessary, certification of any system in which the SRS and SLS products may be used. The requirements specified in 4) above may require special conditions of installation or use to be detailed in the system certificate.



Mr Simon Ganderton
Director of Quality
Penny & Giles Controls Ltd.

24th July 2018